

CERTIFICAT

CERTIFICADO

СЕРТИФИКАТ

認證證書

CERTIFICATE

ZERTIFIKAT



Italia

# COMPLIANCE

with IEC EN 61508 and IEC EN 61511

Certificate No.: TUV IT 23 SIL 0293

CERTIFICATE OWNER: BFE S.r.l.  
via Tonale 70/A  
24061 Albano S. Alessandro (BG)  
Italy

WE HEREWITH CONFIRM THAT

FLOATING BALL VALVES

TRUNNION BALL VALVES

GLOBE VALVES

GATE VALVES

MEET THE SIL REQUIREMENTS DETAILED IN THE ANNEXED TABLES

FOR THE SAFETY FUNCTIONS:

*SIF1: "correct switching on demand (open to closed), and tight for closing phase, in low demand mode of operation"*

*SIF2: "correct switching on demand (closed to open), in low demand mode of operation"*

Examination result: The above reported Valves were found to meet the standard defined requirements of the safety levels detailed in the following table) according to IEC EN 61508 and IEC EN 61511, under fulfillment of the conditions listed in the Report R TUV IT 23 SIL 0261 in its currently valid version, on which this Certificate is based

Examination parameters: Construction/Functional characteristics and reliability and availability parameters of the above Valves

Official Report No.: R TUV IT 23 SIL 0261

Expiry Date October, 25<sup>th</sup> 2026

IT IS TO BE INTENDED THAT THE ABOVE OFFICIAL REPORT AND ITS ANNEXES ARE AN INTEGRAL PART OF THIS DOCUMENT

Reference Standard IEC EN 61508:2010 Part 2, 4, 6, 7  
IEC EN 61511:2016 Part 1, 2, 3

Milan, October, 26<sup>th</sup> 2023



TÜV ITALIA Srl

TÜV ITALIA Srl  
Industrie Service Division  
Managing Director

Alberto Carelli





Italia

## SUMMARY TABLE

<i>E/EE/EP safety-related system (final element)</i>	<b>Floating Ball Valves produced by BFE S.r.l.</b>	
<i>System type</i>	Type A	
<i>Systematic Capability</i>	SC3	
<i>Safety Function Definition</i>	<i>SIF1: "Correct switching on demand (open to closed) and tight for closing phase, in low demand mode of operation"</i>	<i>SIF2: "correct switching on demand (closed to open), in low demand mode of operation"</i>
<i>Max SIL<sup>(1)</sup></i>	<b>SIL3</b>	<b>SIL3</b>
$\lambda_{TOT}$	1,829E-09	1,829E-09
$\lambda_{NE}$	4,376E-10	6,256E-10
$\lambda_S$	0,000E+00	0,000E+00
$\lambda_{DD,PST}^{(2)}$	3,710E-10	8,855E-10
$\lambda_{DU,FPT}$	1,020E-09	3,177E-10
<i><math>\beta</math> and <math>\beta_D</math> factor</i>	10%	10%
<i>MRT</i>	8 h	8 h
<i>Hardware Safety Integrity</i>	Route 2 <sub>H</sub>	Route 2 <sub>H</sub>
<i>Systematic Safety Integrity</i>	Route 2 <sub>s</sub>	Route 2 <sub>s</sub>
<b>Remarks</b>		
<p>(1) The Safety Integrity Level (SIL) of the entire Safety Instrumented Function (SIF) must be verified via a calculation of <math>PFD_{AVG}</math> considering the redundant architectures, proof test interval, proof test effectiveness, any automatic diagnostics, average repair time and the specific failure rates of all products included in the SIF. Each subsystem must be checked to assure compliance with the minimum hardware fault tolerance (HFT) requirements.</p> <p>(2) Considering an automatic Partial Stroke Test.</p>		

SIL classification according to Standard IEC EN 61508 (Chapters: 2, 4, 6, 7) and IEC EN 61511 (Chapters: 1, 2, 3) for Floating Ball Valves produced by BFE S.r.l.

NOTE: The present table is integral part of the Document: TUV IT 23 SIL 0293  
Date: October, 26<sup>th</sup> 2023





Italia

## SUMMARY TABLE

<i>E/EE/EP safety-related system (final element)</i>	<b>Trunnion Ball Valves produced by BFE S.r.l.</b>	
<i>System type</i>	Type A	
<i>Systematic Capability</i>	SC3	
<i>Safety Function Definition</i>	<i>SIF1: "Correct switching on demand (open to closed) and tight for closing phase, in low demand mode of operation"</i>	<i>SIF1: "Correct switching on demand (open to closed) and tight for closing phase, in low demand mode of operation"</i>
<i>Max SIL<sup>(1)</sup></i>	<b>SIL3</b>	<b>SIL3</b>
$\lambda_{TOT}$	8,963E-09	8,963E-09
$\lambda_{NE}$	2,145E-09	2,145E-09
$\lambda_S$	0,000E+00	0,000E+00
$\lambda_{DD,PST}^{(2)}$	1,819E-09	1,819E-09
$\lambda_{DU,FPT}$	5,000E-09	5,000E-09
<i><math>\beta</math> and <math>\beta_D</math> factor</i>	10%	10%
<i>MRT</i>	8 h	8 h
<i>Hardware Safety Integrity</i>	Route 2 <sub>H</sub>	Route 2 <sub>H</sub>
<i>Systematic Safety Integrity</i>	Route 2 <sub>S</sub>	Route 2 <sub>S</sub>
<b>Remarks</b>		
<p>(1) The Safety Integrity Level (SIL) of the entire Safety Instrumented Function (SIF) must be verified via a calculation of <math>PFD_{AVG}</math> considering the redundant architectures, proof test interval, proof test effectiveness, any automatic diagnostics, average repair time and the specific failure rates of all products included in the SIF. Each subsystem must be checked to assure compliance with the minimum hardware fault tolerance (HFT) requirements.</p> <p>(2) Considering an automatic Partial Stroke Test.</p>		

SIL classification according to Standard IEC EN 61508 (Chapters: 2, 4, 6, 7) and IEC EN 61511 (Chapters: 1, 2, 3) for Trunnion Ball Valves produced by BFE S.r.l.

NOTE: The present table is integral part of the Document: TUV IT 23 SIL 0293  
Date: October, 26<sup>th</sup> 2023





Italia

## SUMMARY TABLE

<i>E/EE/EP safety-related system (final element)</i>	Globe Valves produced by BFE S.r.l.	
<i>System type</i>	Type A	
<i>Systematic Capability</i>	SC3	
<i>Safety Function Definition</i>	<i>SIF1: "Correct switching on demand (open to closed) and tight for closing phase, in low demand mode of operation"</i>	<i>SIF2: "correct switching on demand (closed to open), in low demand mode of operation"</i>
<i>Max SIL<sup>(1)</sup></i>	<b>SIL3</b>	<b>SIL3</b>
$\lambda_{TOT}$	1,443E-08	1,443E-08
$\lambda_{NE}$	3,453E-09	4,937E-09
$\lambda_S$	0,000E+00	0,000E+00
$\lambda_{DD,PST}^{(2)}$	2,928E-09	6,987E-09
$\lambda_{DU,FPT}$	8,050E-09	2,507E-09
<i><math>\beta</math> and <math>\beta_D</math> factor</i>	10%	10%
<i>MRT</i>	8 h	8 h
<i>Hardware Safety Integrity</i>	Route 2 <sub>H</sub>	Route 2 <sub>H</sub>
<i>Systematic Safety Integrity</i>	Route 2 <sub>S</sub>	Route 2 <sub>S</sub>
<b>Remarks</b>		
(1) The Safety Integrity Level (SIL) of the entire Safety Instrumented Function (SIF) must be verified via a calculation of $PFD_{AVG}$ considering the redundant architectures, proof test interval, proof test effectiveness, any automatic diagnostics, average repair time and the specific failure rates of all products included in the SIF. Each subsystem must be checked to assure compliance with the minimum hardware fault tolerance (HFT) requirements.		
(2) Considering an automatic Partial Stroke Test.		

SIL classification according to Standard IEC EN 61508 (Chapters: 2, 4, 6, 7) and IEC EN 61511 (Chapters: 1, 2, 3) for Globe Valves produced by BFE S.r.l.

NOTE: The present table is integral part of the Document: TUV IT 23 SIL 0293  
Date: October, 26<sup>th</sup> 2023





Italia

## SUMMARY TABLE

<i>E/EE/EP safety-related system (final element)</i>	<b>Gate Valves produced by BFE S.r.l.</b>	
<i>System type</i>	Type A	
<i>Systematic Capability</i>	SC3	
<i>Safety Function Definition</i>	<i>SIF1: "Correct switching on demand (open to closed) and tight for closing phase, in low demand mode of operation"</i>	<i>SIF2: "correct switching on demand (closed to open), in low demand mode of operation"</i>
<i>Max SIL<sup>(1)</sup></i>	<b>SIL3</b>	<b>SIL3</b>
$\lambda_{TOT}$	2,720E-08	2,720E-08
$\lambda_{NE}$	6,508E-09	9,305E-09
$\lambda_S$	0,000E+00	0,000E+00
$\lambda_{DD,PST}^{(2)}$	5,519E-09	1,317E-08
$\lambda_{DU,FPT}$	1,517E-08	4,725E-09
<i><math>\beta</math> and <math>\beta_D</math> factor</i>	10%	10%
<i>MRT</i>	8 h	8 h
<i>Hardware Safety Integrity</i>	Route 2 <sub>H</sub>	Route 2 <sub>H</sub>
<i>Systematic Safety Integrity</i>	Route 2 <sub>S</sub>	Route 2 <sub>S</sub>
<b>Remarks</b>		
<p>(1) The Safety Integrity Level (SIL) of the entire Safety Instrumented Function (SIF) must be verified via a calculation of <math>PFD_{AVG}</math> considering the redundant architectures, proof test interval, proof test effectiveness, any automatic diagnostics, average repair time and the specific failure rates of all products included in the SIF. Each subsystem must be checked to assure compliance with the minimum hardware fault tolerance (HFT) requirements.</p> <p>(2) Considering an automatic Partial Stroke Test.</p>		

SIL classification according to Standard IEC EN 61508 (Chapters: 2, 4, 6, 7) and IEC EN 61511 (Chapters: 1, 2, 3) for Gate Valves produced by BFE S.r.l.

NOTE: The present table is integral part of the Document: TUV IT 23 SIL 0293  
Date: October, 26<sup>th</sup> 2023